





February 2, 2023

Facility Assessment Budgets Summary

	Early	y Learning Center	E	Elementary School	Middle School	High School	Total
Urgent		None		None	None	None	None
Required	\$	210,000	\$	200,000	\$ 1,760,000	\$ 2,250,000	\$ 4,420,000
Recommended	\$	382,000	\$	439,000	\$ 405,000	\$ 154,000	\$ 1,380,000
TOTALS	\$	592,000	\$	639,000	\$ 2,165,000	\$ 2,404,000	_

TOTAL ASSESSMENT COSTS \$ 5,800,000







Facility Assessment Budgets

ARL	Y LEAR	RNING C	ENTER (ELC)				
em	Urgent	Required	Recommended	SCOPE	BU	JDGET	Notes
XTER	IOR						
			Х	Exterior doors and frames rusting out	\$	7,000	Front entry only
				Front entry most noticeable			
			Х	NE Stair settled on top, handrails exploding out concrete at stairs	\$	25,000	Replace stairs and replace handrail with side mount style
				(1) stairs at east end of building - (12) stair corners at NE stair			
		Х		Playground	\$	10,000	Misc. concrete sidewalks throughout playground area. New
				Not ADA Accessible, needs path from building or parking lot to edge of play area and from edge of play area to the play equipment			rubber surface not included.
ITER	IOR						
			Х	Entrance is not secure	\$	350,000	
				Renovate adjacent classroom into office space and existing office space into classroom			
		Х		Restrooms - not accessible	\$	200,000	Complete renovation of each restroom and adjacent space
				Add (2) new ADA stalls near existing restrooms			·

ELC Summary:

Urgent	None
Required	\$ 210,000
Recommended	\$ 382,000

ELEM	IENTAR	RY SCHO	OL				
Item	Urgent	Required	Recommended	SCOPE	В	UDGET	Notes
EXTER	RIOR						
6.			Χ	Lintels at various openings exposed and need painting to stop rusting	\$	15,000	Grind rust, prime and paint
				(38) windows and (5) opening lintels			
7.			Х	Exterior doors showing rust and need repainting	\$	20,000	Replacement of doors only, fiber glass material
	•	•		(5) double door location			
8.			Х	Brick repair	\$	4,000	Mason and tender for 2 days each
				Window 152 has damaged brick at upper right corner			
				Window 155 & 156 broken brick near grade at corner between them			
INTER	IOR						
9.			Χ	Entrance is not secure	\$	400,000	Assumes relocating new office near entry doors and complete
				Modify entry layout to direct visitors thru office and restrict access to rest of			demolition and renovation of existing office into common space
				building. Relocate Kindergarten door and add (2) new sets of doors			
10		Х		Restrooms - not accessible	\$	50,000	Assumes adequate space and tying into existing plumbing near
							new restroom spaces
				Add (2) new ADA stalls near existing restrooms - (1) for children and (1) for adults			
11.		Х		Locker rooms	\$	150,000	Complete renovation of existing spaces
				Gang showers are no longer allowed, make individual showers. Convert (1) gang			

shower into (1) ADA shower and (2) standard showers with adjacent changing.

Renovate entire locker room areas.

Elementary Summary:

Urgent	None
Required	\$ 200,000
Recommended	\$ 439,000

MIDD	LE SC	HOOL					
Item	Urgent	Required	Recommended	SCOPE	В	UDGET	Notes
EXTER	IOR			<u></u>			
12.			Х	Door frame on west side is rusted out	\$	5,000	
				(1) replaced door & frame			
13.		Х		Playground	\$	10,000	Misc. concrete sidewalks throughout playground area to provide
				Not ADA Accessible, needs path from building or parking lot to edge of play area and from edge of play area to the play equipment			access to equipment, new rubber surface not included
INTER	IOR						
14.			Χ	Entrance is not secure	\$	400,000	
				requires relocating current office to take over classroom at entry and then converting the office area into a classroom.			
15.		Х		Restrooms - not accessible	\$	450,000	Complete renovation of 3 pairs of bathrooms - 6 total, assume
				Add (2) new ADA stalls near existing restrooms - could replace (2) existing side by side single toilets but need additional space.			adequate space for growing restrooms into adjacent spaces
16.		Х		Lower level locker rooms	\$	350,000	(2) lifts (1 per locker room) and renovate both shower areas only
				Not accessible and have gang showers. Provide Lift and individual showers.			
17.		Х		Music & Choir rooms	\$	950,000	Complete renovation of the Music & Choir rooms (3,200SF)
				Not accessible due to permanently tiered floor. Remove tiered floor and provide			

Middle School Summary:

Urgent	None
Required	\$ 1,760,000
Recommended	\$ 405,000

movable platforms

HIGH	SCHOO	OL					
Item	Urgent	Required	Recommended	SCOPE	I	BUDGET	Notes
EXTE	RIOR						
18.			X	Doors 11, M & L	\$	15,000	Remove and replace with fiberglass doors and frames
				Showing heavy rust and needs repainting or replacement			
	1		1	1			
19.			X	North stair handrail	\$		Assumes stairs are salvageable, patch concrete and replace
				Rusting out and exploding concrete. Remove and replace handrail			handrail with side mount style
20.	1		Х	Access Door and (2) overhead door frames (old auto and welding rooms)	Ś	2,000	
20.			^	Showing rust, grind and repaint	Ş	2,000	
				Showing rust, grind and repaint			
21.			Х	(5) Bollards and (2) overhead door frames	Ś	2,000	
			1	Rusting and need to be repainted		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
22.			Х	Bus Lane Pavement	\$	130,000	
				Full of cracks and need replacement (approx. 1,000' x 25' lane)			
HIGH	SCHOO	OL .					
Item	Urgent	_	Recommended	SCOPE		BUDGET	Notes
Item INTE	Urgent	Required	Recommended				
Item	Urgent	_	Recommended	Lower Level Restrooms not accessible	\$		Notes Complete renovation of both restrooms
Item INTE	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing			
Item INTE	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage			
Item INTE	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing			
Item INTEI 23.	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room	\$	100,000	Complete renovation of both restrooms
Item INTE	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair		100,000	
Item INTEI 23.	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room	\$	100,000	Complete renovation of both restrooms
Item INTEI 23.	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to	\$	100,000	Complete renovation of both restrooms
Item INTEI 23.	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room	\$	100,000	Complete renovation of both restrooms
Item INTER 23.	Urgent	X X	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to provide smaller practice room with corridor through	\$	1,200,000	Complete renovation of both restrooms Complete renovation of Music and Choir area
Item INTEI 23.	Urgent	Required	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to provide smaller practice room with corridor through Original locker rooms	\$	1,200,000	Complete renovation of both restrooms
Item INTER 23.	Urgent	X X	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to provide smaller practice room with corridor through Original locker rooms Showers are gang showers, need to replace with (4) individual showers with one of	\$	1,200,000	Complete renovation of both restrooms Complete renovation of Music and Choir area
Item INTER 23.	Urgent	X X	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to provide smaller practice room with corridor through Original locker rooms	\$	1,200,000	Complete renovation of both restrooms Complete renovation of Music and Choir area
Item INTER 23.	Urgent	X X	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to provide smaller practice room with corridor through Original locker rooms Showers are gang showers, need to replace with (4) individual showers with one of the four to be ADA. Locker rooms accessed by stairs, need lift at stage to provide	\$	1,200,000	Complete renovation of both restrooms Complete renovation of Music and Choir area
Item INTER 23.	Urgent	X X	Recommended	Lower Level Restrooms not accessible Provide at least (2) new ADA restrooms near the existing. Could replace (2) existing side by side and back to back single toiles but need additional space. Take storage room or health room Music and Choir not accessible via stair Permanently tiered space. Lift at stage would provide access but Ensemble room would need to be used to access the Choir and Band space. Modify Ensemble to provide smaller practice room with corridor through Original locker rooms Showers are gang showers, need to replace with (4) individual showers with one of the four to be ADA. Locker rooms accessed by stairs, need lift at stage to provide	\$	1,200,000	Complete renovation of both restrooms Complete renovation of Music and Choir area

Showers are gang showers, need to replace with (4) individual showers with a changing area. ADA stall is only 3'-7" wide and needs to be 5'-0". This will take out a urinal in the men's and a standard water closet in the women's. At women's stall could be added by taking two individual showers.

High School Summary:

Urgent	None
Required	\$ 2,250,000
Recommended	\$ 154,000