

# Dashir Management Services, Inc.

---

E8723A County Road H ~ Wisconsin Dells, WI 53965

Phone (608) 253-2000 Fax (608) 253-2000

[www.dashirmanagement.com](http://www.dashirmanagement.com)

## River Valley School District

December 2021

Custodial / Maintenance Report

### Personnel Information

We are currently staffed and doing well.

### Training Conducted

The OSHA required safety training on Indoor Air Quality Awareness was completed for the month of November.

### Inspections

Fire inspectors completed inspections in Spring Green facilities. Corrections being made.

Bleacher inspections were completed. Waiting for results to come back.

### Progress on Projects

- Obtained an estimate for the closet to be added to the classroom at elementary. On hold.
- Foster will be replacing one section of sewer drain pipe in the middle school basement, probably in a couple of months.
- Emptied middle school basement of items stored. Ready for wrestling season.
- Feiner to perform abatement and replace flooring at the high school library over the winter break.
- Requested estimate for future replacement of some plumbing at high school that is in poor condition.
- Received an estimate for a chain link fence to go around the playground at ELC. Working on different avenues.
- Continued daily disinfecting of all schools.
- Received estimate for roof over ELC sandbox. This is on hold for now.
- Approved updating tractor for school. Tractor is about three months out. Trading in existing tractor.
- Requesting estimates for work to be performed at the middle school library.
- Large garage door for the football warehouse was ordered due to it being damaged in the storm.
- Working on replacing boards that have holes in them on the large trailer.
- Looking for estimates to repair awning and replace concrete at the football ticket booth.
- Obtaining estimates for replacing metal handrails and patching concrete stairs.
- Working on getting an assessment of the exhaust system in the high school locker rooms. Existing system unable to keep up. Once an assessment is made, will request a quote.
- Requested estimate for Boiler 2 at high school. The boiler refractory floor is breaking up and getting soft.
- Have started installing whiteboards in the district.
- Irrigation pipes have been blown out.

### Comments

Thank you for your time. If you have a question or concern, please feel free to let me know.

Respectfully Submitted,

Jeni Meuer

Facility Manager